

# FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO  
The Lubrizol Corporation

AUTHORIZING THE OPERATION OF  
Lubrizol Deer Park  
Utilities, Maintenance, and Waste Management  
Other Basic Organic Chemical Manufacturing

LOCATED AT  
Harris County, Texas  
Latitude 29° 43' 5" Longitude 95° 6' 57"  
Regulated Entity Number: RN100221589

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No: O1929 Issuance Date: \_\_\_\_\_

\_\_\_\_\_  
For the Commission

## Table of Contents

Section	Page
General Terms and Conditions .....	1
Special Terms and Conditions: .....	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements .....	9
New Source Review Authorization Requirements .....	9
Compliance Requirements.....	10
Risk Management Plan .....	12
Protection of Stratospheric Ozone .....	12
Temporary Fuel Shortages (30 TAC § 112.15) .....	12
Permit Location .....	13
Permit Shield (30 TAC § 122.148) .....	13
Attachments .....	14
Applicable Requirements Summary.....	15
Additional Monitoring Requirements .....	64
Permit Shield .....	73
New Source Review Authorization References .....	80
Appendix A.....	87
Acronym List .....	88

## **General Terms and Conditions**

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

## **Special Terms and Conditions:**

### **Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting**

1. Permit holder shall comply with the following requirements:
  - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
  - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
  - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
  - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.

- E. Emission units subject to 40 CFR Part 63, Subpart FFFF as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.890 which incorporates the 40 CFR Part 63 Subpart by reference.
- F. Emission units subject to 40 CFR Part 63, Subpart ZZZZ as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1090 which incorporates the 40 CFR Part 63 Subpart by reference.
- G. Emission units subject to 40 CFR Part 63, Subpart DDDDD as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1130 which incorporates the 40 CFR Part 63 Subpart by reference.
- H. For the purpose of generating emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 1 (Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
  - (i) Title 30 TAC § 101.302 (relating to General Provisions)
  - (ii) Title 30 TAC § 101.303 (relating to Emission Reduction Credit Generation Certification)
  - (iii) Title 30 TAC § 101.304 (relating to Mobile Emission Reduction Credit Generation and Certification)
  - (iv) Title 30 TAC § 101.309 (relating to Emission Credit Banking and Trading)
  - (v) The terms and conditions by which the emission limits are established to generate the reduction credit are applicable requirements of this permit
- I. The permit holder shall comply with the following 30 TAC Chapter 101, Subchapter H, Division 3 (Mass Emission Cap and Trade Program) Requirements:
  - (i) Title 30 TAC § 101.352 (relating to General Provisions)
  - (ii) Title 30 TAC § 101.353 (relating to Allocation of Allowances)
  - (iii) Title 30 TAC § 101.354 (relating to Allowance Deductions)
  - (iv) Title 30 TAC § 101.356 (relating to Allowance Banking and Trading)
  - (v) Title 30 TAC § 101.359 (relating to Reporting)
  - (vi) Title 30 TAC § 101.360 (relating to Level of Activity Certification)
  - (vii) The terms and conditions by which the emission limits are established to meet or exceed the cap are applicable requirements of this permit
- J. For the purpose of generating discrete emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 4 (Discrete Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
  - (i) Title 30 TAC § 101.372 (relating to General Provisions)
  - (ii) Title 30 TAC § 101.373 (relating to Discrete Emission Reduction Credit Generation and Certification)

- (iii) Title 30 TAC § 101.374 (relating to Mobile Discrete Emission Reduction Credit Generation and Certification)
    - (iv) Title 30 TAC § 101.378 (relating to Discrete Emission Credit Banking and Trading)
    - (v) The terms and conditions by which the emission limits are established to generate the discrete reduction credit are applicable requirements of this permit
  - K. The permit holder shall comply with the following 30 TAC Chapter 101, Subchapter H, Division 6 (Highly Reactive Volatile Organic Compound Emissions Cap and Trade Program) requirements:
    - (i) Title 30 TAC § 101.393 (relating to General Provisions)
    - (ii) Title 30 TAC § 101.394 (relating to Allocation of Allowances)
    - (iii) Title 30 TAC § 101.396 (relating to Allowance Deductions)
    - (iv) Title 30 TAC § 101.399 (relating to Allowance Banking and Trading)
    - (v) Title 30 TAC § 101.400 (relating to Reporting)
    - (vi) The terms and conditions by which the emission limits are established to meet or exceed the cap are applicable requirements of this permit
2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
- A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
  - B. Title 30 TAC § 101.3 (relating to Circumvention)
  - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
  - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
  - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
  - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
  - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
  - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
  - I. Title 30 TAC § 101.222 (relating to Demonstrations)
  - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:

- A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity averaged over a six minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:
- (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
  - (ii) Title 30 TAC § 111.111(a)(1)(E)
  - (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
  - (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO<sub>x</sub>, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the "Applicable Requirements Summary" attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:
    - (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
    - (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
    - (3) Records of all observations shall be maintained.
    - (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the

plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(5) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from a building, enclosed facility, or other structure; the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(7)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(7)(B)(i) or (ii)
- (iii) For a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source subject to 30 TAC § 111.111(a)(7)(A), complying with 30 TAC § 111.111(a)(7)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO<sub>x</sub>, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
  - (1) An observation of visible emissions from a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source which is required to comply with 30 TAC § 111.111(a)(7)(A) shall be conducted at least once during each

calendar quarter unless the air emission source or enclosed facility is not operating for the entire quarter.

- (2) Records of all observations shall be maintained.
- (3) Visible emissions observations of air emission sources or enclosed facilities operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of air emission sources or enclosed facilities operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each emissions outlet in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each emissions outlet during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
- (4) Compliance Certification:
  - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(7) and (a)(7)(A)
  - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(7)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

C. For visible emissions from all other sources not specified in 30 TAC § 111.111(a)(1), (4), or (7); the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(8)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(8)(B)(i) or (ii)



- (iii) For a source subject to 30 TAC § 111.111(a)(8)(A), complying with 30 TAC § 111.111(a)(8)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO<sub>x</sub>, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
- (1) An observation of visible emissions from a source which is required to comply with 30 TAC § 111.111(a)(8)(A) shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter.
  - (2) Records of all observations shall be maintained.
  - (3) Visible emissions observations of sources operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of sources operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each source during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
  - (4) Compliance Certification:
    - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A)
    - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
- D. For emission units with contributions from uncombined water, the permit holder shall comply with the requirements of 30 TAC § 111.111(b).

- E. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
  - (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
  - (ii) Sources with an effective stack height ( $h_e$ ) less than the standard effective stack height ( $H_e$ ), must reduce the allowable emission level by multiplying it by  $[h_e/H_e]^2$  as required in 30 TAC § 111.151(b)
  - (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)
- 4. Permit holder shall comply with the following 30 TAC Chapter 115, Subchapter C requirements:
  - A. When filling stationary gasoline storage vessels (Stage I) for motor vehicle fuel dispensing facilities, constructed prior to November 15, 1992, with transfers to stationary storage tanks located at a facility which has dispensed no more than 10,000 gallons of gasoline in any calendar month after January 1, 1991, the permit holder shall comply with the following requirements specified in 30 TAC Chapter 115, Subchapter C:
    - (i) Title 30 TAC § 115.222(3) (relating to Control Requirements), as it applies to liquid gasoline leaks, visible vapors, or significant odors
    - (ii) Title 30 TAC § 115.222(6) (relating to Control Requirements)
    - (iii) Title 30 TAC § 115.224(1) (relating to Inspection Requirements), as it applies to liquid gasoline leaks, visible vapors, or significant odors
    - (iv) Title 30 TAC § 115.226(2)(B) (relating to Recordkeeping Requirements)
- 5. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:
  - A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
  - B. Title 40 CFR § 60.8 (relating to Performance Tests)
  - C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
  - D. Title 40 CFR § 60.12 (relating to Circumvention)
  - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
  - F. Title 40 CFR § 60.14 (relating to Modification)
  - G. Title 40 CFR § 60.15 (relating to Reconstruction)
  - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
- 6. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.

7. For miscellaneous chemical process facilities subject to maintenance wastewater requirements as specified in 40 CFR § 63.2485, Table 7, the permit holder shall comply with the requirements of 40 CFR § 63.105 (relating to Maintenance Wastewater Requirements) (Title 30 TAC Chapter 113, Subchapter C, § 113.890 incorporated by reference).
8. For miscellaneous chemical process facilities with Group 2 wastewater streams subject to wastewater operations requirements in 40 CFR Part 63, Subpart FFFF, the permit holder shall comply with the requirements of 40 CFR § 63.132(a), (a)(1), (a)(1)(i), and (a)(3) as specified in § 63.2485(a) (Title 30 TAC Chapter 113, Subchapter C, § 113.890 incorporated by reference).

#### **Additional Monitoring Requirements**

9. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time or minimum frequency specified in the "Periodic Monitoring Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

#### **New Source Review Authorization Requirements**

10. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, material safety data sheets (MSDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144.
  - A. If applicable, monitoring of control device performance or general work practice standards shall be made in accordance with the TCEQ Periodic Monitoring Guidance document.
  - B. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).
11. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule, standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
  - A. Are incorporated by reference into this permit as applicable requirements

- B. Shall be located with this operating permit
  - C. Are not eligible for a permit shield
12. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
  13. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).
  14. The permit holder shall comply with the following requirements for Air Quality Standard Permits:
    - A. Registration requirements listed in 30 TAC § 116.611, unless otherwise provided for in an Air Quality Standard Permit
    - B. General Conditions listed in 30 TAC § 116.615, unless otherwise provided for in an Air Quality Standard Permit
    - C. Boiler Standard Permit

### **Compliance Requirements**

15. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
16. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
17. Permit holder shall comply with the following 30 TAC Chapter 117 requirements:
  - A. The permit holder shall comply with the compliance schedules and submit written notification to the TCEQ Executive Director as required in 30 TAC Chapter 117, Subchapter H, Division 1:
    - (i) For sources in the Houston-Galveston-Brazoria Nonattainment area, 30 TAC § 117.9020:

(1) Title 30 TAC § 117.9020(2)(A), (C), and (D)

- B. The permit holder shall comply with the Initial Control Plan unit listing requirement in 30 TAC § 117.350(c) and (c)(1).
- C. The permit holder shall comply with the requirements of 30 TAC § 117.354 for Final Control Plan Procedures for Attainment Demonstration Emission Specifications and 30 TAC § 117.356 for Revision of Final Control Plan.

18. Use of Emission Credits to comply with applicable requirements:

- A. Unless otherwise prohibited, the permit holder may use emission credits to comply with the following applicable requirements listed elsewhere in this permit:
  - (i) Title 30 TAC Chapter 115
  - (ii) Title 30 TAC Chapter 117
  - (iii) Offsets for Title 30 TAC Chapter 116
- B. The permit holder shall comply with the following requirements in order to use the emission credits to comply with the applicable requirements:
  - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.306(c)-(d)
  - (ii) The emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 1
  - (iii) The executive director has approved the use of the credit according to 30 TAC § 101.306(c)-(d)
  - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.302(g) and 30 TAC Chapter 122
  - (v) Title 30 TAC § 101.305 (relating to Emission Reductions Achieved Outside the United States)

19. Use of Discrete Emission Credits to comply with the applicable requirements:

- A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
  - (i) Title 30 TAC Chapter 115
  - (ii) Title 30 TAC Chapter 117
  - (iii) If applicable, offsets for Title 30 TAC Chapter 116
  - (iv) Temporarily exceed state NSR permit allowables
- B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:

- (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
- (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
- (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
- (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
- (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

### **Risk Management Plan**

- 20. For processes subject to 40 CFR Part 68 and specified in 40 CFR § 68.10, the permit holder shall comply with the requirements of the Accidental Release Prevention Provisions in 40 CFR Part 68. The permit holder shall submit to the appropriate agency either a compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR § 68.10(a), or as part of the compliance certification submitted under this permit, a certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of a risk management plan.

### **Protection of Stratospheric Ozone**

- 21. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone:
  - A. Any on site servicing, maintenance, and repair on refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants or non-exempt substitutes shall be conducted in accordance with 40 CFR Part 82, Subpart F. Permit holders shall ensure that repairs on or refrigerant removal from refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart F.

### **Temporary Fuel Shortages (30 TAC § 112.15)**

- 22. The permit holder shall comply with the following 30 TAC Chapter 112 requirements:
  - A. Title 30 TAC § 112.15 (relating to Temporary Fuel Shortage Plan Filing Requirements)
  - B. Title 30 TAC § 112.16(a), (a)(1), and (a)(2)(B) - (C) (relating to Temporary Fuel Shortage Plan Operating Requirements)
  - C. Title 30 TAC § 112.17 (relating to Temporary Fuel Shortage Plan Notification Procedures)
  - D. Title 30 TAC § 112.18 (relating to Temporary Fuel Shortage Plan Reporting Requirements)

**Permit Location**

23. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

**Permit Shield (30 TAC § 122.148)**

24. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

## **Attachments**

**Applicable Requirements Summary**

**Additional Monitoring Requirements**

**Permit Shield**

**New Source Review Authorization References**



### **Applicable Requirements Summary**

<b>Unit Summary .....</b>	<b>16</b>
---------------------------	-----------

<b>Applicable Requirements Summary .....</b>	<b>22</b>
--	-----------

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
BB-500	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
BB-500/4LR	Loading/Unloading Operations	N/A	R5211-0001B	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
BB-504	Storage Tanks/Vessels	N/A	R5112-0002	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
BB-510	Storage Tanks/Vessels	N/A	R5112-0002	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
BB-510-LR	Loading/Unloading Operations	N/A	R5211-0001B	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
BB-511	Storage Tanks/Vessels	N/A	R5112-0002	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
BB-512	Storage Tanks/Vessels	N/A	R5112-0002	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
BB-518	Storage Tanks/Vessels	N/A	R5112-0003	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
BB-518-LR	Loading/Unloading Operations	N/A	R5211-0001B	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
BB-519	Storage Tanks/Vessels	N/A	R5112-0003	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
BB-520	Storage Tanks/Vessels	N/A	R5112-0003	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
BBWO-1	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
BBWO-1-LR	Loading/Unloading Operations	N/A	R5211-0001B	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
BOILER#4	Boilers/Steam Generators/Steam Generating Units	N/A	R7310-0002	30 TAC Chapter 117, Subchapter B	No changing attributes.
BOILER#4	Boilers/Steam Generators/Steam Generating Units	N/A	63DDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
BOILER#5	Boilers/Steam Generators/Steam Generating Units	N/A	R7310-0003	30 TAC Chapter 117, Subchapter B	No changing attributes.

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
BOILER#5	Boilers/Steam Generators/Steam Generating Units	N/A	63DDDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
BOILER#6	Boilers/Steam Generators/Steam Generating Units	N/A	R7310-0002	30 TAC Chapter 117, Subchapter B	No changing attributes.
BOILER#6	Boilers/Steam Generators/Steam Generating Units	N/A	63DDDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
BOILER#7	Boilers/Steam Generators/Steam Generating Units	N/A	R7310-0002	30 TAC Chapter 117, Subchapter B	No changing attributes.
BOILER#7	Boilers/Steam Generators/Steam Generating Units	N/A	60DC-0001	40 CFR Part 60, Subpart Dc	No changing attributes.
BOILER#7	Boilers/Steam Generators/Steam Generating Units	N/A	63DDDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
BOILER#8	Boilers/Steam Generators/Steam Generating Units	N/A	R7310-0002	30 TAC Chapter 117, Subchapter B	No changing attributes.
BOILER#8	Boilers/Steam Generators/Steam Generating Units	N/A	60DC-0001	40 CFR Part 60, Subpart Dc	No changing attributes.
BOILER#8	Boilers/Steam Generators/Steam Generating Units	N/A	63DDDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
CC-515	Storage Tanks/Vessels	N/A	R5112-0002	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
CC-515-LR	Loading/Unloading Operations	N/A	R5211-0001B	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
CC-517	Storage Tanks/Vessels	N/A	R5112-0002	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
DSL-1	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
DSL-1-LR	Loading/Unloading Operations	N/A	R5211-0001B	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
DSL-2-LR	Loading/Unloading Operations	N/A	R5211-0001B	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
E-12	Storage Tanks/Vessels	N/A	R5112-0003	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
E-6	Storage Tanks/Vessels	N/A	R5112-0003	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
ENPUCIWA	SRIC Engines	N/A	R7303-0001	30 TAC Chapter 117, Subchapter B	No changing attributes.
ENPUCIWA	SRIC Engines	N/A	60III-0002	40 CFR Part 60, Subpart IIII	No changing attributes.
ENPUCIWA	SRIC Engines	N/A	63ZZZZ-0001	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ENPUEDOM	SRIC Engines	N/A	R7303-0001	30 TAC Chapter 117, Subchapter B	No changing attributes.
ENPUEDOM	SRIC Engines	N/A	60III-0002	40 CFR Part 60, Subpart IIII	No changing attributes.
ENPUEDOM	SRIC Engines	N/A	63ZZZZ-0003	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ENPUFIRE	SRIC Engines	N/A	R7303-0002	30 TAC Chapter 117, Subchapter B	No changing attributes.
ENPUFIRE	SRIC Engines	N/A	63ZZZZ-0002	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ENPUWS3	SRIC Engines	N/A	R7303-0001	30 TAC Chapter 117, Subchapter B	No changing attributes.
ENPUWS3	SRIC Engines	N/A	60III-0002	40 CFR Part 60, Subpart IIII	No changing attributes.
ENPUWS3	SRIC Engines	N/A	63ZZZZ-0001	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ENPUWS5	SRIC Engines	N/A	R7303-0002	30 TAC Chapter 117, Subchapter B	No changing attributes.
ENPUWS5	SRIC Engines	N/A	63ZZZZ-0002	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ENPUS#1LS	SRIC Engines	N/A	R7303-0001	30 TAC Chapter 117, Subchapter B	No changing attributes.
ENPUS#1LS	SRIC Engines	N/A	60III-0002	40 CFR Part 60, Subpart IIII	No changing attributes.
ENPUS#1LS	SRIC Engines	N/A	63ZZZZ-0001	40 CFR Part 63, Subpart ZZZZ	No changing attributes.

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
ENPUWFIRE	SRIC Engines	N/A	R7303-0002	30 TAC Chapter 117, Subchapter B	No changing attributes.
ENPUWFIRE	SRIC Engines	N/A	63ZZZZ-0002	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GE116	SRIC Engines	N/A	R7303-0002	30 TAC Chapter 117, Subchapter B	No changing attributes.
GE116	SRIC Engines	N/A	63ZZZZ-0002	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GEADMIN	SRIC Engines	N/A	R7303-0001	30 TAC Chapter 117, Subchapter B	No changing attributes.
GEADMIN	SRIC Engines	N/A	60III-0002	40 CFR Part 60, Subpart IIII	No changing attributes.
GEADMIN	SRIC Engines	N/A	63ZZZZ-0003	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GEGATE14	SRIC Engines	N/A	R7303-0002	30 TAC Chapter 117, Subchapter B	No changing attributes.
GEGATE14	SRIC Engines	N/A	63ZZZZ-0002	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GEMMB	SRIC Engines	N/A	R7303-0001	30 TAC Chapter 117, Subchapter B	No changing attributes.
GEMMB	SRIC Engines	N/A	60III-0002	40 CFR Part 60, Subpart IIII	No changing attributes.
GEMMB	SRIC Engines	N/A	63ZZZZ-0001	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GEPSMILL	SRIC Engines	N/A	R7303-0001	30 TAC Chapter 117, Subchapter B	No changing attributes.
GEPSMILL	SRIC Engines	N/A	60III-0001	40 CFR Part 60, Subpart IIII	No changing attributes.
GEPSMILL	SRIC Engines	N/A	63ZZZZ-0002	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GET55	SRIC Engines	N/A	R7303-0001	30 TAC Chapter 117, Subchapter B	No changing attributes.
GET55	SRIC Engines	N/A	63ZZZZ-0002	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GEWORKS	SRIC Engines	N/A	R7303-0002	30 TAC Chapter 117, Subchapter B	No changing attributes.
GEWORKS	SRIC Engines	N/A	63ZZZZ-0002	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GEWWTP	SRIC Engines	N/A	R7303-0001	30 TAC Chapter 117, Subchapter B	No changing attributes.
GEWWTP	SRIC Engines	N/A	60III-0002	40 CFR Part 60, Subpart IIII	No changing attributes.
GEWWTP	SRIC Engines	N/A	63ZZZZ-0001	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
OVS-1	Volatile Organic Compound	N/A	R5131-0003	30 TAC Chapter 115, Water Separation	No changing attributes.

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	Water Separators				
OVS-2	Volatile Organic Compound Water Separators	N/A	R5131-0003	30 TAC Chapter 115, Water Separation	No changing attributes.
OVS-3	Volatile Organic Compound Water Separators	N/A	R5131-0001	30 TAC Chapter 115, Water Separation	No changing attributes.
OVS-4	Volatile Organic Compound Water Separators	N/A	R5131-0001	30 TAC Chapter 115, Water Separation	No changing attributes.
RA-3	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
SL-2	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
SL-3	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
T-19X	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
T-19X-LR	Loading/Unloading Operations	N/A	R5211-0001B	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
T-20X	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
T-29X	Volatile Organic Compound Water Separators	N/A	R5131-0003	30 TAC Chapter 115, Water Separation	No changing attributes.
T-30X	Volatile Organic Compound Water Separators	N/A	R5131-0003	30 TAC Chapter 115, Water Separation	No changing attributes.
T-40	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
T-41	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
T-42	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TC-1	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TC-1-LR	Loading/Unloading Operations	N/A	R5211-0001B	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
WO-11	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
WO-12	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
WO-13	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
WO-13	Storage Tanks/Vessels	N/A	63FFFFWW-0001	40 CFR Part 63, Subpart FFFF	No changing attributes.
WO-13-LR	Loading/Unloading Operations	N/A	R5211-0001A	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
WO-15	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
WO-15-LR	Loading/Unloading Operations	N/A	R5211-0001B	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
WO-17	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
WO-18	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
WO-4	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
WO-4-LR	Loading/Unloading Operations	N/A	R5211-0001B	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
WW-3	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
WW-4	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
WW-5	Storage Tanks/Vessels	N/A	R5112-0001	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
WW-5-LR	Loading/Unloading Operations	N/A	R5211-0001B	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BB-500	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
BB-500/4LR	EU	R5211-0001B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
BB-504	EU	R5112-0002	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
BB-510	EU	R5112-0002	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
BB-510-LR	EU	R5211-0001B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None



### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						this division, except as specified.			
BB-511	EU	R5112-0002	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
BB-512	EU	R5112-0002	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
BB-518	EU	R5112-0003	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
BB-518-LR	EU	R5211-0001B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
BB-519	EU	R5112-0003	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						1.5 psia is exempt from the requirements of this division.			
BB-520	EU	R5112-0003	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
BBWO-1	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
BBWO-1-LR	EU	R5211-0001B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
BOILER#4	EU	R7310-0002	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(B) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.340(p)(3)	electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)		§ 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
BOILER#4	EU	R7310-0002	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
BOILER#4	EU	63DDDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
BOILER#5	EU	R7310-0003	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a)	An owner or operator may not use the alternative	[G]§ 117.335(a)(1) § 117.335(a)(4)	§ 117.345(a) § 117.345(f)	§ 117.335(b) § 117.335(g)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(1) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	[G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
BOILER#5	EU	R7310-0003	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.310(c)(3) § 117.340(f)(1) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120(1) § 117.8120(1)(A)		§ 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
BOILER#5	EU	63DDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
BOILER#6	EU	R7310-0002	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(B) § 117.310(b) [G]§ 117.310(e)(1)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)		§ 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
BOILER#6	EU	R7310-0002	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
BOILER#6	EU	63DDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					specification requirements of 40 CFR Part 63, Subpart DDDDD		DDDDD	DDDDD	
BOILER#7	EU	R7310-0002	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(B) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
BOILER#7	EU	R7310-0002	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)		[G]§ 117.8010(8)
BOILER#7	EU	60DC-0001	SO <sub>2</sub>	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
BOILER#7	EU	60DC-0001	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
BOILER#7	EU	60DC-0001	PM (Opacity)	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
BOILER#7	EU	63DDDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
BOILER#8	EU	R7310-0002	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a)	An owner or operator may not use the alternative	[G]§ 117.335(a)(1) § 117.335(a)(4)	§ 117.345(a) § 117.345(f)	§ 117.335(b) § 117.335(g)



### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.310(a)(1)(B) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(f)(1) § 117.345(f)(9)	§ 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
BOILER#8	EU	R7310-0002	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
BOILER#8	EU	60DC-0001	SO <sub>2</sub>	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed,	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3)	[G]§ 60.48c(a) § 60.48c(j)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).		§ 60.48c(i)	
BOILER#8	EU	60DC-0001	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
BOILER#8	EU	60DC-0001	PM (Opacity)	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
BOILER#8	EU	63DDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
CC-515	EU	R5112-0002	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CC-515-LR	EU	R5211-0001B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
CC-517	EU	R5112-0002	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
DSL-1	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
DSL-1-LR	EU	R5211-0001B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
DSL-2-LR	EU	R5211-0001B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						than 0.5 psia is exempt from the requirements of this division, except as specified.			
E-12	EU	R5112-0003	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
E-6	EU	R5112-0003	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
ENPUCIWA	EU	R7303-0001	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
ENPUCIWA	EU	60III-0002	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and less than 130 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
ENPUCIWA	EU	60III-0002	NMHC and NO <sub>x</sub>	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO <sub>x</sub> emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
ENPUCIWA	EU	60III-0002	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than 130 KW and a	None	None	[G]§ 60.4214(d)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4218 § 89.112(a)	displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.30 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
ENPUCIWA	EU	63ZZZZ-0001	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ENPUEDOM	EU	R7303-0001	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)			
ENPUEDOM	EU	60III-0002	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
ENPUEDOM	EU	60III-0002	NMHC and NO <sub>x</sub>	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO <sub>x</sub> emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
ENPUEDOM	EU	60III-0002	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
ENPUEDOM	EU	63ZZZZ-0003	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(b)(1) § 63.6595(c) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	An affected source which meets either of the criteria in paragraphs §63.6590(b)(1)(i)-(ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of §63.6645(f).	None	None	§ 63.6645(c) § 63.6645(f)
ENPUEFIRE	EU	R7303-0002	Exempt	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None



### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.			
ENPUEFIRE	EU	63ZZZZ-0002	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(f) § 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii	§ 63.6625(i) § 63.6655(d) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ENPUEWS3	EU	R7303-0001	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
ENPUEWS3	EU	60III-0002	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
ENPUEWS3	EU	60III-0002	NMHC and NO <sub>x</sub>	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO <sub>x</sub> emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
ENPUEWS3	EU	60III-0002	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and	None	None	[G]§ 60.4214(d)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4211(f) § 60.4218 § 89.112(a)	less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
ENPUEWS3	EU	63ZZZZ-0001	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ENPUEWS5	EU	R7303-0002	Exempt	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.			
ENPUEWS5	EU	63ZZZZ-0002	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(f) § 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii	§ 63.6625(i) § 63.6655(d) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ENPUS#1LS	EU	R7303-0001	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
ENPUS#1LS	EU	60III-0002	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
ENPUS#1LS	EU	60III-0002	NMHC and NO <sub>x</sub>	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO <sub>x</sub> emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
ENPUS#1LS	EU	60III-0002	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and	None	None	[G]§ 60.4214(d)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4211(f) § 60.4218 § 89.112(a)	less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
ENPUS#1LS	EU	63ZZZZ-0001	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ENPUWFIRE	EU	R7303-0002	Exempt	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.			
ENPUWFIRE	EU	63ZZZZ-0002	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(f) § 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii	§ 63.6625(i) § 63.6655(d) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
GE116	EU	R7303-0002	Exempt	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
GE116	EU	63ZZZZ-0002	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1)	For each existing emergency stationary CI	§ 63.6625(f) § 63.6625(i)	§ 63.6625(i) § 63.6655(d)	§ 63.6640(e) § 63.6650(f)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii	§ 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	
GEADMIN	EU	R7303-0001	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
GEADMIN	EU	60III-0002	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007	None	None	[G]§ 60.4214(d)



### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
GEADMIN	EU	60III-0002	NMHC and NO <sub>x</sub>	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO <sub>x</sub> emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
GEADMIN	EU	60III-0002	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GEADMIN	EU	63ZZZZ-0003	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(b)(1) § 63.6595(c) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	An affected source which meets either of the criteria in paragraphs §63.6590(b)(1)(i)-(ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of §63.6645(f).	None	None	§ 63.6645(c) § 63.6645(f)
GEGATE14	EU	R7303-0002	Exempt	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
GEGATE14	EU	63ZZZZ-0002	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(f) § 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii	§ 63.6625(i) § 63.6655(d) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6640(f)(2)(i) § 63.6640(f)(3)				
GEMMB	EU	R7303-0001	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
GEMMB	EU	60III-0002	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GEMMB	EU	60III-0002	NMHC and NO <sub>x</sub>	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO <sub>x</sub> emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
GEMMB	EU	60III-0002	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
GEMMB	EU	63ZZZZ-0001	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section	None	None	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
GEPSMILL	EU	R7303-0001	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
GEPSMILL	EU	60III-0001	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(a)-Table 1 § 60.4206 § 60.4207(b) § 60.4211(b) § 60.4211(b)(1) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and a displacement of less than 10 liters per cylinder and is	None	None	[G]§ 60.4214(d)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						a pre-2007 model year must comply with a CO emission limit of 11.4 g/KW-hr, as listed in Table 1 to this subpart.			
GEPSMILL	EU	60III-0001	Hydrocarbons	40 CFR Part 60, Subpart IIII	§ 60.4205(a)-Table 1 § 60.4206 § 60.4207(b) § 60.4211(b) § 60.4211(b)(1) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and a displacement of less than 10 liters per cylinder and is a pre-2007 model year must comply with an HC emission limit of 1.3 g/KW-hr, as listed in Table 1 to this subpart.	None	None	[G]§ 60.4214(d)
GEPSMILL	EU	60III-0001	NO <sub>x</sub>	40 CFR Part 60, Subpart IIII	§ 60.4205(a)-Table 1 § 60.4206 § 60.4207(b) § 60.4211(b) § 60.4211(b)(1) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and a displacement of less than 10 liters per cylinder and is a pre-2007 model year must comply with a NO <sub>x</sub> emission limit of 9.2 g/KW-hr, as listed in Table 1 to this subpart.	None	None	[G]§ 60.4214(d)
GEPSMILL	EU	60III-0001	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(a)-Table 1 § 60.4206 § 60.4207(b) § 60.4211(b) § 60.4211(b)(1) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and a displacement of less than	None	None	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4218	10 liters per cylinder and is a pre-2007 model year must comply with a PM emission limit of 0.54 g/KW-hr, as listed in Table 1 to this subpart.			
GEPSMILL	EU	63ZZZZ-0002	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(f) § 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii	§ 63.6625(i) § 63.6655(d) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
GET55	EU	R7303-0001	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
GET55	EU	63ZZZZ-0002	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1)	For each existing emergency stationary CI	§ 63.6625(f) § 63.6625(i)	§ 63.6625(i) § 63.6655(d)	§ 63.6640(e) § 63.6650(f)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii	§ 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	
GEWORKS	EU	R7303-0002	Exempt	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
GEWORKS	EU	63ZZZZ-0002	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(f) § 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii	§ 63.6625(i) § 63.6655(d) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)



### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GEWWTP	EU	R7303-0001	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
GEWWTP	EU	60III-0002	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
GEWWTP	EU	60III-0002	NMHC and NO <sub>x</sub>	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206	Owners and operators of emergency stationary CI ICE, that are not fire pump	None	None	[G]§ 60.4214(d)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
GEWWTP	EU	60III-0002	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
GEWWTP	EU	63ZZZZ-0001	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements	None	None	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
OWS-1	EU	R5131-0003	VOC	30 TAC Chapter 115, Water Separation	§ 115.132(a)(1)	VOC water separators must have each compartment totally enclosed with all openings sealed. Gauging and sampling devices shall be vapor-tight except during use.	[G]§ 115.135(a) § 115.136(a)(3) § 115.136(a)(4) ** See Periodic Monitoring Summary	§ 115.136(a)(3) § 115.136(a)(4)	None
OWS-2	EU	R5131-0003	VOC	30 TAC Chapter 115, Water Separation	§ 115.132(a)(1)	VOC water separators must have each compartment totally enclosed with all openings sealed. Gauging and sampling devices shall be vapor-tight except during use.	[G]§ 115.135(a) § 115.136(a)(3) § 115.136(a)(4) ** See Periodic Monitoring Summary	§ 115.136(a)(3) § 115.136(a)(4)	None
OWS-3	EU	R5131-0001	VOC	30 TAC Chapter 115, Water Separation	§ 115.137(a)(2) [G]§ 115.132(a)(4)	Any single or multiple compartment VOC water separator which separates materials having a true vapor pressure of VOC < .5 psia obtained from any equipment is exempt from §115.132(a).	[G]§ 115.135(a) § 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	None
OWS-4	EU	R5131-0001	VOC	30 TAC Chapter 115, Water Separation	§ 115.137(a)(2) [G]§ 115.132(a)(4)	Any single or multiple compartment VOC water separator which separates materials having a true vapor pressure of VOC < .5 psia obtained from any equipment is exempt from	[G]§ 115.135(a) § 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						§115.132(a).			
RA-3	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
SL-2	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
SL-3	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
T-19X	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
T-19X-LR	EU	R5211-0001B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						this division, except as specified.			
T-20X	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
T-29X	EU	R5131-0003	VOC	30 TAC Chapter 115, Water Separation	§ 115.132(a)(1)	VOC water separators must have each compartment totally enclosed with all openings sealed. Gauging and sampling devices shall be vapor-tight except during use.	[G]§ 115.135(a) § 115.136(a)(3) § 115.136(a)(4) ** See Periodic Monitoring Summary	§ 115.136(a)(3) § 115.136(a)(4)	None
T-30X	EU	R5131-0003	VOC	30 TAC Chapter 115, Water Separation	§ 115.132(a)(1)	VOC water separators must have each compartment totally enclosed with all openings sealed. Gauging and sampling devices shall be vapor-tight except during use.	[G]§ 115.135(a) § 115.136(a)(3) § 115.136(a)(4) ** See Periodic Monitoring Summary	§ 115.136(a)(3) § 115.136(a)(4)	None
T-40	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
T-41	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						division.			
T-42	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
TC-1	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
TC-1-LR	EU	R5211-0001B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
WO-11	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
WO-12	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						requirements of this division.			
WO-13	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
WO-13	EU	63FFFFWW-0001	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2485(a) § 63.133(a)(1) § 63.2485(b)	You must meet each requirement in Table 7 to this subpart that applies: §63.133(a)(1) - The owner or operator shall operate and maintain a fixed roof	None	None	§ 63.146(b)(2) § 63.146(b)(5) § 63.2450(q)
WO-13-LR	EU	R5211-0001A	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
WO-15	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
WO-15-LR	EU	R5211-0001B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						than 0.5 psia is exempt from the requirements of this division, except as specified.			
WO-17	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
WO-18	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
WO-4	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
WO-4-LR	EU	R5211-0001B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
WW-3	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5)	None



### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				VOCs		storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.		§ 115.118(a)(7)	
WW-4	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
WW-5	EU	R5112-0001	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
WW-5-LR	EU	R5211-0001B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None

**Additional Monitoring Requirements**

**Periodic Monitoring Summary ..... 65**

## Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OWS-1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Water Separation	SOP Index No.: R5131-0003
Pollutant: VOC	Main Standard: § 115.132(a)(1)
Monitoring Information	
Indicator: VOC Concentration	
Minimum Frequency: Annually	
Averaging Period: n/a	
<p>Deviation Limit: For a potential leak interface other than a seal around a shaft that passes through a cover opening, the maximum deviation limit is 500 ppmv. For a seal around a shaft that passes through a cover opening, the maximum deviation limit is 10,000 ppmv.</p>	
<p>Periodic Monitoring Text: Measure and record the VOC concentration using a portable analyzer to monitor VOC concentration around the immediate area of the compartment in accordance with 40 CFR Part 60, Appendix A, Method 21. Each potential leak interface (i.e., a location where organic vapor leakage could occur) on the cover and associated closer devices shall be checked. Potential leak interfaces that are associated with covers and closure devices include, but are not limited to: the interface of the cover and its foundation mounting; the periphery of any opening on the cover and its associated closure device; and the sealing seat interface on a spring-loaded pressure relief valve. The owner or operator may choose to adjust the detection instrument readings for the background organic concentration level.</p> <p>The monitoring instrumentation shall be maintained and operated in accordance with manufacturer's specifications or other written procedures.</p> <p>Any monitoring data greater than the maximum VOC limit indicated in the Deviation Limit above shall be considered and reported as a deviation as required by § 122.145(2).</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OWS-1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Water Separation	SOP Index No.: R5131-0003
Pollutant: VOC	Main Standard: § 115.132(a)(1)
Monitoring Information	
Indicator: Visual Inspection	
Minimum Frequency: Monthly	
Averaging Period: n/a	
Deviation Limit: Any monitoring data that indicates a crack or gap in a sealed opening.	
<p>Periodic Monitoring Text: The oil-water separator and its closure devices shall be visually inspected by the owner operator to check for defects that could result in air emissions. Defects include, but are not limited to, visible cracks, holes, or gaps in the roof sections or between the roof and the separator wall; broken, cracked, or otherwise damaged seals or gaskets on closure devices; and broken or missing hatches, access covers, caps, or other closure devices.</p> <p>Any monitoring data that indicates a gap or crack in a sealed opening shall be considered and reported as a deviation as required by § 122.145(2).</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OWS-2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Water Separation	SOP Index No.: R5131-0003
Pollutant: VOC	Main Standard: § 115.132(a)(1)
Monitoring Information	
Indicator: VOC Concentration	
Minimum Frequency: Annually	
Averaging Period: n/a	
<p>Deviation Limit: For a potential leak interface other than a seal around a shaft that passes through a cover opening, the maximum deviation limit is 500 ppmv. For a seal around a shaft that passes through a cover opening, the maximum deviation limit is 10,000 ppmv.</p> <p>Periodic Monitoring Text: Measure and record the VOC concentration using a portable analyzer to monitor VOC concentration around the immediate area of the compartment in accordance with 40 CFR Part 60, Appendix A, Method 21. Each potential leak interface (i.e., a location where organic vapor leakage could occur) on the cover and associated closer devices shall be checked. Potential leak interfaces that are associated with covers and closure devices include, but are not limited to: the interface of the cover and its foundation mounting; the periphery of any opening on the cover and its associated closure device; and the sealing seat interface on a spring-loaded pressure relief valve. The owner or operator may choose to adjust the detection instrument readings for the background organic concentration level.</p> <p>The monitoring instrumentation shall be maintained and operated in accordance with manufacturer's specifications or other written procedures.</p> <p>Any monitoring data greater than the maximum VOC limit indicated in the Deviation Limit above shall be considered and reported as a deviation as required by § 122.145(2).</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OWS-2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Water Separation	SOP Index No.: R5131-0003
Pollutant: VOC	Main Standard: § 115.132(a)(1)
Monitoring Information	
Indicator: Visual Inspection	
Minimum Frequency: Monthly	
Averaging Period: n/a	
Deviation Limit: Any monitoring data that indicates a crack or gap in a sealed opening.	
<p>Periodic Monitoring Text: The oil-water separator and its closure devices shall be visually inspected by the owner operator to check for defects that could result in air emissions. Defects include, but are not limited to, visible cracks, holes, or gaps in the roof sections or between the roof and the separator wall; broken, cracked, or otherwise damaged seals or gaskets on closure devices; and broken or missing hatches, access covers, caps, or other closure devices.</p> <p>Any monitoring data that indicates a gap or crack in a sealed opening shall be considered and reported as a deviation as required by § 122.145(2).</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: T-29X	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Water Separation	SOP Index No.: R5131-0003
Pollutant: VOC	Main Standard: § 115.132(a)(1)
Monitoring Information	
Indicator: VOC Concentration	
Minimum Frequency: Annually	
Averaging Period: n/a	
<p>Deviation Limit: For a potential leak interface other than a seal around a shaft that passes through a cover opening, the maximum deviation limit is 500 ppmv. For a seal around a shaft that passes through a cover opening, the maximum deviation limit is 10,000 ppmv.</p>	
<p>Periodic Monitoring Text: Measure and record the VOC concentration using a portable analyzer to monitor VOC concentration around the immediate area of the compartment in accordance with 40 CFR Part 60, Appendix A, Method 21. Each potential leak interface (i.e., a location where organic vapor leakage could occur) on the cover and associated closer devices shall be checked. Potential leak interfaces that are associated with covers and closure devices include, but are not limited to: the interface of the cover and its foundation mounting; the periphery of any opening on the cover and its associated closure device; and the sealing seat interface on a spring-loaded pressure relief valve. The owner or operator may choose to adjust the detection instrument readings for the background organic concentration level.</p> <p>The monitoring instrumentation shall be maintained and operated in accordance with manufacturer's specifications or other written procedures.</p> <p>Any monitoring data greater than the maximum VOC limit indicated in the Deviation Limit above shall be considered and reported as a deviation as required by § 122.145(2).</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: T-29X	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Water Separation	SOP Index No.: R5131-0003
Pollutant: VOC	Main Standard: § 115.132(a)(1)
Monitoring Information	
Indicator: Visual Inspection	
Minimum Frequency: Monthly	
Averaging Period: n/a	
Deviation Limit: Any monitoring data that indicates a crack or gap in a sealed opening.	
<p>Periodic Monitoring Text: The oil-water separator and its closure devices shall be visually inspected by the owner operator to check for defects that could result in air emissions. Defects include, but are not limited to, visible cracks, holes, or gaps in the roof sections or between the roof and the separator wall; broken, cracked, or otherwise damaged seals or gaskets on closure devices; and broken or missing hatches, access covers, caps, or other closure devices.</p> <p>Any monitoring data that indicates a gap or crack in a sealed opening shall be considered and reported as a deviation as required by § 122.145(2).</p>	



### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: T-30X	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Water Separation	SOP Index No.: R5131-0003
Pollutant: VOC	Main Standard: § 115.132(a)(1)
Monitoring Information	
Indicator: VOC Concentration	
Minimum Frequency: Annually	
Averaging Period: n/a	
<p>Deviation Limit: For a potential leak interface other than a seal around a shaft that passes through a cover opening, the maximum deviation limit is 500 ppmv. For a seal around a shaft that passes through a cover opening, the maximum deviation limit is 10,000 ppmv.</p>	
<p>Periodic Monitoring Text: Measure and record the VOC concentration using a portable analyzer to monitor VOC concentration around the immediate area of the compartment in accordance with 40 CFR Part 60, Appendix A, Method 21. Each potential leak interface (i.e., a location where organic vapor leakage could occur) on the cover and associated closer devices shall be checked. Potential leak interfaces that are associated with covers and closure devices include, but are not limited to: the interface of the cover and its foundation mounting; the periphery of any opening on the cover and its associated closure device; and the sealing seat interface on a spring-loaded pressure relief valve. The owner or operator may choose to adjust the detection instrument readings for the background organic concentration level.</p> <p>The monitoring instrumentation shall be maintained and operated in accordance with manufacturer's specifications or other written procedures.</p> <p>Any monitoring data greater than the maximum VOC limit indicated in the Deviation Limit above shall be considered and reported as a deviation as required by § 122.145(2).</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: T-30X	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Water Separation	SOP Index No.: R5131-0003
Pollutant: VOC	Main Standard: § 115.132(a)(1)
Monitoring Information	
Indicator: Visual Inspection	
Minimum Frequency: Monthly	
Averaging Period: n/a	
Deviation Limit: Any monitoring data that indicates a crack or gap in a sealed opening.	
<p>Periodic Monitoring Text: The oil-water separator and its closure devices shall be visually inspected by the owner operator to check for defects that could result in air emissions. Defects include, but are not limited to, visible cracks, holes, or gaps in the roof sections or between the roof and the separator wall; broken, cracked, or otherwise damaged seals or gaskets on closure devices; and broken or missing hatches, access covers, caps, or other closure devices.</p> <p>Any monitoring data that indicates a gap or crack in a sealed opening shall be considered and reported as a deviation as required by § 122.145(2).</p>	

**Permit Shield**

**Permit Shield ..... 74**

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
116MNDEG	N/A	30 TAC Chapter 115, Degreasing Processes	Remote reservoir cold cleaners with tvp <0.6 psia @100 F drain area <16 in2 waste solvent disposed of in closed containers
116MNDEG	N/A	40 CFR Part 63, Subpart T	Chlorinated solvents are not used in this solvent degreaser
156MNDEG	N/A	30 TAC Chapter 115, Degreasing Processes	Remote reservoir cold cleaners with tvp <0.6 psia @100 F drain area <16 in2 waste solvent disposed of in closed containers
156MNDEG	N/A	40 CFR Part 63, Subpart T	Chlorinated solvents are not used in this solvent degreaser
BB-500	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity greater than 151 m3 and storing a VOL with a maximum true vapor pressure less than 3.5 kPa
BB-504	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity greater than 151 m3 and storing a VOL with a maximum true vapor pressure less than 3.5 kPa
BB-510	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity greater than or equal to 75 m3 and less than 151 m3 and storing a VOL with a maximum true vapor pressure less than 15 kPa
BB-511	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity greater than or equal to 75 m3 and less than 151 m3 and storing a VOL with a maximum true vapor pressure less than 15 kPa
BB-512	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity greater than or equal to 75 m3 and less than 151 m3 and storing a VOL with a maximum true vapor pressure less than 15 kPa
BB-518	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity greater than 151 m3 and storing a VOL with a maximum true vapor pressure less than 3.5 kPa
BB-519	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity greater than 151 m3 and storing a VOL with a maximum true vapor pressure less than 3.5 kPa
BB-520	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity greater than 151 m3 and storing a VOL with a maximum true vapor pressure less than 3.5 kPa

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
BBWO-1	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
BOILER#4	N/A	40 CFR Part 60, Subpart D	The facility is not a fossil-fuel steam generating unit greater than 250 million Btu per hour heat input rate
BOILER#4	N/A	40 CFR Part 60, Subpart Da	The facility is not an electrical generating steam generating unit greater than 250 million Btu per hour heat input rate
BOILER#4	N/A	40 CFR Part 60, Subpart Db	The facility is not a steam generating unit greater than 100 million Btu per hour heat input rate
BOILER#4	N/A	40 CFR Part 60, Subpart Dc	Constructed prior to 6/9/1989
BOILER#5	N/A	40 CFR Part 60, Subpart D	The facility is not a fossil-fuel steam generating unit greater than 250 million Btu per hour heat input rate
BOILER#5	N/A	40 CFR Part 60, Subpart Da	The facility is not an electrical generating steam generating unit greater than 250 million Btu per hour heat input rate
BOILER#5	N/A	40 CFR Part 60, Subpart Db	Constructed prior to 6/19/1984
BOILER#5	N/A	40 CFR Part 60, Subpart Dc	Constructed prior to 6/9/1989
BOILER#6	N/A	40 CFR Part 60, Subpart D	The facility is not a fossil-fuel steam generating unit greater than 250 million Btu per hour heat input rate
BOILER#6	N/A	40 CFR Part 60, Subpart Da	The facility is not an electrical generating steam generating unit greater than 250 million Btu per hour heat input rate
BOILER#6	N/A	40 CFR Part 60, Subpart Db	The facility is not a steam generating unit greater than 100 million Btu per hour heat input rate
BOILER#6	N/A	40 CFR Part 60, Subpart Dc	Constructed prior to 6/9/1989
BOILER#7	N/A	40 CFR Part 60, Subpart D	The facility is not a fossil-fuel steam generating unit greater than 250 million Btu per hour heat input rate

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
BOILER#7	N/A	40 CFR Part 60, Subpart Da	The facility is not an electrical generating steam generating unit greater than 250 million Btu per hour heat input rate
BOILER#7	N/A	40 CFR Part 60, Subpart Db	The facility is not a steam generating unit greater than 100 million Btu per hour heat input rate
BOILER#8	N/A	40 CFR Part 60, Subpart D	The facility is not a fossil-fuel steam generating unit greater than 250 million Btu per hour heat input rate
BOILER#8	N/A	40 CFR Part 60, Subpart Da	The facility is not an electrical generating steam generating unit greater than 250 million Btu per hour heat input rate
BOILER#8	N/A	40 CFR Part 60, Subpart Db	The facility is not a steam generating unit greater than 100 million Btu per hour heat input rate
BOILERTOTES	N/A	30 TAC Chapter 115, Storage of VOCs	Storage tank less than 1,000 gallons
BOILERTOTES	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
BRINETK	N/A	30 TAC Chapter 115, Storage of VOCs	Storage tank does not contain a volatile organic compound
BRINETK	N/A	40 CFR Part 60, Subpart Kb	Storage vessel does not contain a volatile organic liquid
CC-515	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity greater than or equal to 75 m3 and less than 151 m3 and storing a VOL with a maximum true vapor pressure less than 15 kPa
CC-517	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity greater than or equal to 75 m3 and less than 151 m3 and storing a VOL with a maximum true vapor pressure less than 15 kPa
DSL-1	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
DSL-2	N/A	30 TAC Chapter 115, Storage of VOCs	Storage tank less than 1,000 gallons
DSL-2	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
E-12	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity greater than 151 m3 and storing a VOL with a maximum true vapor pressure less than 3.5 kPa
E-6	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity greater than 151 m3 and storing a VOL with a maximum true vapor pressure less than 3.5 kPa
GAS-1	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	Loading facility is a motor vehicle fuel dispensing facility
GAS-1	N/A	30 TAC Chapter 115, Storage of VOCs	Storage tank with capacity less than 25000 gallons located at a motor vehicle fuel dispensing facility
GAS-1	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
OWS-1	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
OWS-2	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
OWS-3	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
OWS-4	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
PMPREBDEG	N/A	30 TAC Chapter 115, Degreasing Processes	Remote reservoir cold cleaners with tvp <0.6 psia @100 F drain area <16 in2 waste solvent disposed of in closed containers.
PMPREBDEG	N/A	40 CFR Part 63, Subpart T	Chlorinated solvents are not used in this solvent degreaser.
PMPSHDEG1	N/A	30 TAC Chapter 115, Degreasing Processes	Remote reservoir cold cleaners with tvp <0.6 psia @100 F drain area <16 in2 waste solvent disposed of in closed containers.
PMPSHDEG1	N/A	40 CFR Part 63, Subpart T	Chlorinated solvents are not used in this solvent degreaser.
PMPSHDEG2	N/A	30 TAC Chapter 115, Degreasing Processes	Remote reservoir cold cleaners with tvp <0.6 psia @100 F drain area <16 in2 waste solvent disposed of in closed containers.
PMPSHDEG2	N/A	40 CFR Part 63, Subpart T	Chlorinated solvents are not used in this solvent degreaser.
PMPSHDEG3	N/A	30 TAC Chapter 115, Degreasing	Remote reservoir cold cleaners with tvp <0.6 psia @100 F drain

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
		Processes	area <16 in2 waste solvent disposed of in closed containers.
PMPSHDEG3	N/A	40 CFR Part 63, Subpart T	Chlorinated solvents are not used in this solvent degreaser
QALABDEG	N/A	30 TAC Chapter 115, Degreasing Processes	Remote reservoir cold cleaners with tvp <0.6 psia @100 F drain area <16 in2 waste solvent disposed of in closed containers.
QALABDEG	N/A	40 CFR Part 63, Subpart T	Chlorinated solvents are not used in this solvent degreaser
RA-3	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
SL-2	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
SL-3	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
SS-57	N/A	30 TAC Chapter 115, Storage of VOCs	Storage tank less than 1,000 gallons
SS-57	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
T-19X	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
T-20X	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
T-40	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
T-41	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
T-42	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
TC-1	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
TOOLRMDEG	N/A	30 TAC Chapter 115, Degreasing Processes	Remote reservoir cold cleaners with tvp <0.6 psia @100 F drain area <16 in2 waste solvent disposed of in closed containers.
TOOLRMDEG	N/A	40 CFR Part 63, Subpart T	Chlorinated solvents are not used in this solvent degreaser
WO-11	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
WO-12	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3



### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
WO-13	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
WO-15	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
WO-17	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
WO-18	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
WO-4	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
WW-3	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity less than 75 m3
WW-4	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity greater than 151 m3 and storing a VOL with a maximum true vapor pressure less than 3.5 kPa
WW-5	N/A	40 CFR Part 60, Subpart Kb	Storage vessel having a capacity greater than 151 m3 and storing a VOL with a maximum true vapor pressure less than 3.5 kPa
WWTP	N/A	30 TAC Chapter 115, Industrial Wastewater	Wastewater streams do not meet the definition of an affected VOC wastewater stream as defined in §115.140(2)

**New Source Review Authorization References**

<b>New Source Review Authorization References .....</b>	<b>81</b>
<b>New Source Review Authorization References by Emission Unit .....</b>	<b>82</b>

### New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 150134	Issuance Date: 02/08/2018
Authorization No.: 19804	Issuance Date: 08/11/2015
Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 106.263	Version No./Date: 11/01/2001
Number: 106.371	Version No./Date: 09/04/2000
Number: 106.433	Version No./Date: 09/04/2000
Number: 106.451	Version No./Date: 09/04/2000
Number: 106.452	Version No./Date: 09/04/2000
Number: 106.454	Version No./Date: 11/01/2001
Number: 106.472	Version No./Date: 09/04/2000
Number: 106.473	Version No./Date: 09/04/2000
Number: 106.476	Version No./Date: 09/04/2000
Number: 106.511	Version No./Date: 09/04/2000
Number: 106.532	Version No./Date: 09/04/2000

### New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
116MNDEG	SOLVENT DEGREASER	106.454/11/01/2001
156MNDEG	SOLVENT DEGREASER	106.454/11/01/2001
BB-500/4LR	LOADING/UNLOADING NONHAZWASTE	19804
BB-500	STORAGE NONHAZWASTE	19804
BB-504	STORAGE NONHAZWASTE	19804
BB-510-LR	LOADING/UNLOADING NONHAZWASTE	19804
BB-510	STORAGE NONHAZWASTE	19804
BB-511	STORAGE NONHAZWASTE	19804
BB-512	STORAGE NONHAZWASTE	19804
BB-518-LR	LOADING/UNLOADING NONHAZWASTE	19804
BB-518	STORAGE NONHAZWASTE	19804
BB-519	STORAGE NONHAZWASTE	19804
BB-520	STORAGE NONHAZWASTE	19804
BBWO-1-LR	LOADING/UNLOADING WASTE	19804
BBWO-1	STORAGE WASTE	19804
BOILER#4	BOILER #4	19804
BOILER#5	BOILER #5	19804
BOILER#6	BOILER #6	19804
BOILER#7	BOILER #7	150134
BOILER#8	BOILER #8	150134
BOILERTOTES	STORAGE TANKS	106.371/09/04/2000

### New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
BRINETK	STORAGE TANK	106.371/09/04/2000
CC-515-LR	LOADING/UNLOADING NONHAZWASTE	19804
CC-515	STORAGE NONHAZWASTE	19804
CC-517	STORAGE NONHAZWASTE	19804
DSL-1-LR	LOADING/UNLOADING DIESEL	106.472/09/04/2000
DSL-1	STORAGE DIESEL	106.472/09/04/2000
DSL-2-LR	LOADING/UNLOADING DIESEL	106.472/09/04/2000
DSL-2	STORAGE DIESEL	106.472/09/04/2000
E-12	STORAGE TANK	106.532/09/04/2000
E-6	WASTEWATER SURGE	106.532/09/04/2000
ENPUCIWA	EMERGENCY ENGINE	106.511/09/04/2000
ENPUEDOM	EMERGENCY ENGINE	106.511/09/04/2000
ENPUFIRE	EMERGENCY ENGINE	106.511/09/04/2000
ENPUWS3	EMERGENCY ENGINE	106.511/09/04/2000
ENPUWS5	EMERGENCY ENGINE	106.511/09/04/2000
ENPUS#1LS	EMERGENCY ENGINE	106.511/09/04/2000
ENPUWFIRE	EMERGENCY ENGINE	106.511/09/04/2000
GAS-1	GASOLINE STORAGE TANK	106.473/09/04/2000
GE116	EMERGENCY ENGINE	106.511/09/04/2000
GEADMIN	EMERGENCY ENGINE	106.511/09/04/2000
GEGATE14	EMERGENCY ENGINE	106.511/09/04/2000

### New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
GEMMB	EMERGENCY ENGINE	106.511/09/04/2000
GEPSMILL	EMERGENCY ENGINE	106.511/09/04/2000
GET55	EMERGENCY ENGINE	106.511/09/04/2000
GEWORKS	EMERGENCY ENGINE	106.511/09/04/2000
GEWWTP	EMERGENCY ENGINE	106.511/09/04/2000
OWS-1	OIL WATER SEPARATOR	106.532/09/04/2000
OWS-2	OIL WATER SEPARATOR	106.532/09/04/2000
OWS-3	OIL WATER SEPARATOR	106.532/09/04/2000
OWS-4	OIL WATER SEPARATOR	106.532/09/04/2000
PMPREBDEG	SOLVENT DEGREASER	106.454/11/01/2001
PMPSHDEG1	SOLVENT DEGREASER	106.454/11/01/2001
PMPSHDEG2	SOLVENT DEGREASER	106.454/11/01/2001
PMPSHDEG3	SOLVENT DEGREASER	106.454/11/01/2001
QALABDEG	SOLVENT DEGREASER	106.454/11/01/2001
RA-3	WASTE OIL STABILIZATION	106.472/09/04/2000
SL-2	WASTE OIL STORAGE	106.532/09/04/2000
SL-3	SEDIMENTATION COLLECTION	106.532/09/04/2000
SS-57	STORAGE TANK	106.476/09/04/2000
T-19X-LR	LOADING/UNLOADING BIOSLUDGE	106.472/09/04/2000
T-19X	WWT BIOSLUDGE TANK	106.532/09/04/2000
T-20X	WWT ORGANIC DECANT TANK	106.532/09/04/2000

### New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
T-29X	API SEPARATOR - #1 LS	106.532/09/04/2000
T-30X	API SEPARATOR - #1 LS	106.532/09/04/2000
T-40	OIL SKIM TANK	106.532/09/04/2000
T-41	SOLID/SLUDGE WASTE TANK	106.532/09/04/2000
T-42	SLOP OIL TANK	106.532/09/04/2000
TC-1-LR	LOADING/UNLOADING WASTE OIL	19804
TC-1	WASTE OIL STORAGE AND STABILIZATION	19804
TOOLRMDEG	SOLVENT DEGREASER	106.454/11/01/2001
WO-11	WASTE OIL STABILIZATION	106.532/09/04/2000
WO-12	WASTE OIL STABILIZATION	106.532/09/04/2000
WO-13-LR	LOADING HAZWASTE	19804
WO-13	STORAGE HAZ WASTE	19804
WO-15-LR	LOADING/UNLOADING WASTE OIL	106.472/09/04/2000
WO-15	WASTE OIL STABILIZATION	106.532/09/04/2000
WO-17	WASTE OIL STABILIZATION	106.532/09/04/2000
WO-18	WASTE OIL STABILIZATION	106.532/09/04/2000
WO-4-LR	LOADING/UNLOADING NONHAZWASTE	19804
WO-4	STORAGE NONHAZWASTE	19804
WW-3	WASTE OIL STORAGE AND STABILIZATION	19804
WW-4	WASTEWATER SURGE	19804
WW-5-LR	UNLOADING WASTE OIL	19804

### **New Source Review Authorization References by Emissions Unit**

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

<b>Unit/Group/Process ID No.</b>	<b>Emission Unit Name/Description</b>	<b>New Source Review Authorization</b>
WW-5	WASTE OIL STABILIZATION	19804
WWTP	WASTEWATER TREATMENT PROCESS	106.532/09/04/2000



**Appendix A**

**Acronym List ..... 88**

## Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
CEMS	continuous emissions monitoring system
CFR	Code of Federal Regulations
COMS	continuous opacity monitoring system
CVS	closed vent system
D/FW	Dallas/Fort Worth (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H <sub>2</sub> S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MACT	Maximum Achievable Control Technology (40 CFR Part 63)
MMBtu/hr	Million British thermal units per hour
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NESHAP	National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61)
NO <sub>x</sub>	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PEMS	predictive emissions monitoring system
PM	particulate matter
ppmv	parts per million by volume
PRO	process unit
PSD	prevention of significant deterioration
psia	pounds per square inch absolute
SIP	state implementation plan
SO <sub>2</sub>	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound